



## bindex fire and acoustic sealant

**bindex fire and acoustic sealant** is an acrylic based sealant designed to stop sound, smoke and fire from passing through gaps in fire rated walls.

It has been fire tested in Australia for control joints, perimeter seals and penetration seals around cables and metal pipes. When it is exposed to heat, it provides a fire barrier by expanding and forming a solid charred material.

The acrylic formulation means water wash up, easier application, a paintable surface and low volatile chemical content for a low odour product. **bindex fire sealant** can be used during plasterboard installation to replace the need for setting joints in multi-layer systems and butt joints in single layer systems.

### performance

#### Fire

Good body for easy placement of daubs and great initial grip.

#### Acoustics

Maintains the acoustic rating of Siniat systems up to at least Rw 66 and Rw+Ctr 55.

#### Colour

Blue for easy identification

### key benefits

- Excellent slump resistance
- Easy to apply and tool off
- Excellent adhesion to most common building materials



## product information

product size	600mL foil tube
drying time	>Tack Free Time: 60 minutes maximum >Skin Time: 20 minutes maximum
density	1.60 - 1.64 g/cm <sup>3</sup>
solids content	80% minimum
limitations	Should not be used in permanently damp areas or in joints with high movement
clean up	Wash with water before cured
shelf life	At least 12 months when stored in unopened packaging at temperatures between 5°C and 30°C
maximum joint movement	12.5%
systems usage	✓Fire rated
voc	<50g/L

## application

All surfaces must be clean and free from dirt and grease. Use a brush to remove loose material. Lightly apply water or diluted **bindex fire and acoustic sealant** to porous materials to improve bonding. The surfaces may be damp but not running wet. For the best bond, overlap **bindex fire and acoustic sealant** onto the material surfaces. The application range is in temperatures between +5°C and +40°C.

Single layer butt joints and multi-layer recessed and butt joints can be jointed with **bindex fire sealant** and maintain the fire rating of Siniat wall systems. A bead of sealant is applied along the edge of a face layer sheet of plasterboard, then the next sheet is butted up against the first sheet. Sealant must squeeze out of the joint. Excess sealant may be scraped off or left as is. Single layer butt joints must be backed with framing.

## optimise product performance by:

- Storing under cool dry conditions.
- Avoid storage temperatures above 30°C and below 5°C.



## application

Single layer Siniat wall systems must have pipe and cable penetrations surrounded by an additional layer of **fireshield** laminated 100mm out from the penetration to both sides of the wall. This creates the tested thickness of plasterboard in the vicinity of the penetration of at least 26mm. Use 10g laminating screws at maximum 100mm centres. The minimum stud wall thickness must be 103mm. Holes for penetrations for pipes and cables must be no closer than 40mm from each other.

### backing materials

The best way to accurately control sealant depth is to use backing material (e.g. Polyethylene foam or Polyurethane backing rod). Cable tray openings are lined with steel track and the cavity may be stuffed with a backing material the same depth as the stud, such as Polyethylene foam. Control joints must use a backing material such as Polyethylene foam or Polyurethane backing rod. Pipe and cable penetrations can be sealed with foam backing or by using the 'no backing material' technique. Refer to Siniat Blueprint. To apply Polyurethane backing rod to a pipe penetrating a cavity wall or ceiling;

- Cut a piece of rod to the length of the circumference of the pipe
- Join the rod around the pipe using tape
- Push the circle of foam rod past the plasterboard, just until it enters the wall cavity.

To seal around cables or metal pipes without a backing material;

- Use a nozzle cut to a diameter which is appropriate for the gap. For example, use a 5mm diameter nozzle for a small gap of 5mm to 10mm.
- Apply sealant, attempt to fill gap to the full depth of plasterboard by filling outwards
- Apply an extra bead of sealant 10mm high
- Push this bead into the gap with a small tool
- Apply a 20mm fillet as shown in the construction details

### perimeter seals

Fill a gap by applying the sealant from the back of the cavity or joint, filling outwards in a smooth and continuous action. Push sealant into the gap as it is finished flush with the joint sides within five minutes of application, before surface skinning occurs. A small amount of shrinkage will occur on curing. If a flush finish is required, fill the joint slightly proud of the surface to allow for shrinkage.

The fire testing standard, AS1530.4 has permissible variations to tested systems that are useful for **bindex fire and acoustic sealant**:

- *Results obtained from framed wall systems may be applied to the performance of a system in concrete, masonry or solid gypsum blocks of greater or equal thickness to that of the tested prototype. The reverse does not apply.*
- *Results obtained from a prototype test may be applied to framed wall systems of similar construction but having thicker facings of the same material applied to the studs.*



Quality  
ISO 9001



All Siniat products have been developed to meet the specific needs of the Australian market. Products manufactured in Australia comply with quality systems certified as complying with AS/NZS ISO 9001:2008 and meet the requirements of AS/NZS 2588, Gypsum Plasterboard.



The following Siniat products have been independently certified by Global GreenTag to GreenRate Level A: **mastashield**, **fireshield**, **fireshield h**, **soundshield**, **watershield**, **spanshield**, **multishield**, **curveshield**, **opal**, **trurock** and **trurock hd**. Compliance certificates are available on [siniat.com.au](http://siniat.com.au).



All Siniat plasterboard and metal products are available on the Siniat Carbon Neutral Opt-In program to help you meet your sustainability goals. Visit [siniat.com.au](http://siniat.com.au) to find out more.

#### Disclaimer

Products manufactured and systems designed by Etex Australia Pty Ltd and branded Siniat, are produced in accordance with the Building Code of Australia and relevant Australian Standards. Information in this document is to be used as a guide only and is subject to project approval as many aspects of construction are not comprehensively covered. It is also the responsibility of the project to determine if Siniat's products and systems are suitable for the intended application. Etex Australia Pty Ltd will not be held responsible for any claims resulting from the installation of its products or other associated products not in accordance with the recommendations of the manufacturer's technical literature or relevant Australian Standards. Siniat technical information is regularly updated. To ensure this document is current with the latest information, visit [siniat.solutions](http://siniat.solutions)

#### Siniat.solutions provides a host of online solutions for your product

#### **siniat SELECT**<sup>®</sup>

offers an online system selector and custom design specification proposal, developed by us and catered to your project's requirements.

#### **siniat CALCULATE**<sup>®</sup>

is a range of online calculation tools for the professional. Explore [siniat.solutions](http://siniat.solutions) on [siniat.com.au](http://siniat.com.au).



**Etex Australia Pty Ltd**

ABN 61 003 621 010  
31 Military Road, Matraville  
NSW 2036

[siniat.com.au](http://siniat.com.au)



#### warranty

Siniat's products are guaranteed by a 10 Year Warranty. For details visit [siniat.com.au](http://siniat.com.au)

technical advice  
**AU 1300 724 505**