

VOC Content Test Certificate

Monday 5th July 2021

Supplier: Etex Australia Pty Ltd (31 Military Road, Matraville, NSW, 2036, Australia).

Sample Description: Siniat Box Ready Mastaline

Date Tested: June 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05: Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by Green Building Council of Australia for adhesives and sealants in Green Star – Design & As Built V1.3.

Test Data:


<p align="center">Specification</p> <p align="center">Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B Good Environment Choice Australia</p>	<p align="center">Siniat Box Ready Mastaline</p>
<p align="center">General Purpose Adhesive and Sealants Limit: 50 grams per liter</p>	<p align="center">1 gram per Litre as VOC content per material</p>
<p align="center">Meets GBCA VOC Content Requirement</p>	<p align="center">Yes</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Srikanth C Srivatsa
PhD (Chemistry)
Consultant

V2106051