

# VOC Content Test Certificate

Monday 5<sup>th</sup> July 2021

Supplier: Etex Australia Pty Ltd (31 Military Road, Matraville, NSW, 2036, Australia).

Sample Description: Siniat Mastabond

Date Tested: June 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05: Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by Green Building Council of Australia for adhesives and sealants in Green Star – Design & As Built V1.3.

Test Data:


<p align="center"><b>Specification</b></p> <p align="center"><b>Green Building Council of Australia</b> Green Star Design &amp; As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B Good Environment Choice Australia</p>	<p><b>Siniat Mastabond</b></p>
<p align="center"><b>General Purpose Adhesive and Sealants Limit:</b> ≤ 50 grams per liter</p>	<p><b>1 gram per Litre as VOC content per material</b></p>
<p><b>Meets GBCA VOC Content Requirement</b></p>	<p><b>Yes</b></p>



Dr. Vyt Garnys  
PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
ACA, AIRAH, FMA  
Managing Director and Principal Consultant



Dr. Tuan Duong  
PhD, BE (Chem. Eng.)  
Senior Consultant



Srikanth C Srivatsa  
PhD (Chemistry)  
Consultant

**V2106051**